



May 29, 2022  
Reference: 522201E

To  
Niv Saidman  
VP Marketing  
Saidman Engineering

Re: **Product approval for use with drinking water**

Based on SII test certificate no. 7212206606 for complying  
with the requirements of SI 5452 (2016)

In accordance with the instructions of the Israeli Ministry of Health and after testing a representative sample of the product and receiving the relevant information for it, we have no objection to the use of a two-component ceramic polymeric paint made by "A.W. Chesterton Co.", U.S.A, for use in drinking water lines up to 40°C.

The approval refers to the following models:

ARC S1 PW BLU  
ARC S1 PW WH

Any modification of the product or its composition requires further examination and re-approval.

This correspondence does not constitute a recommendation to use the mentioned product, and should not be published in the mass media.

This approval is valid until August 14, 2024.

Sincerely,  
Assaf Amram  
Head of Water section  
Chemistry, Food and Water Branch

**This document is not approval for marking the product with the Standards Mark**

The information in this approval will be published in "search engine drinking water SI 5452" on the SII site