Tube Sheet

Power-Fossil — Circ & Service Water System
ARC S2 Coating
Case Study 125

Challenge

Issue

Increase turbine maintenance due to severe corrosion at tube to tube sheet ligament. Frequency of plugging was reducing condenser efficiency.

Goals

- Reduce turbine maintenance costs
- Eliminate corrosion at tube to tube sheet ligament

Root Cause

Galvanic corrosion between copper tubes and carbon steel tube sheet.



Original condition of the tube sheet

Solution

Preparation

- Plugging ~18,000 tubes to protect from blast cleaning
- Grit blast to Sa 2.5 with 3 mils (75 μm) angular profile

Application

1. Apply 2 coats of ARC S2 at wft of 8-13 mils (200-325 μ m) per coat


Results

Client Reported

- At 3 year service inspection interval equipment considered in excellent condition
- Client rates condenser at 98% efficiency of new
- Based on results to date and data from similar equipment, client indicates expectation of ARC service life to 12+ years



Tube Sheet after S2 application, prior to plug removal



Completed tube sheet